

FIRE SAFETY CERTIFICATE

No. CB-2600000269

Dated: 13/09/2026

Certified that the BHASKAR ACADEMY INDORE (name of the building or premises) at KHASRA No. 171/1 VILLAGE- RINGNODIYA TEHSIL- SANWER, INDORE (address) comprised of Zero (0) basement(s) and Gr+3 floor (upper floors) owned/ occupied by BHASKAR ACADEMY INDORE (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 13/09/2026 (date of inspection) in the presence of Admin. Officer (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes Nursery to 12th (X/ XII) With effect from 13/09/2026 for a period of 1 year year in accordance with rule and subject to compliance of specific conditions as appended:-

- 1.
- 2.
- 3.
- 4.

Issued on 13/09/2026 (date of issue) at M.P.E Nagar Palika Indore (place) by

*Strike out whichever is not applicable.

PRANAV UPADHYAY
B.E. FIRE & SAFETY
Mob. 8871903534
13/09/26

Signature with Seal:

Name

PRANAV UPADHYAY

Designation

Grant Reg. Fire Consultant

Name & Address of Department/ Office:

M.P.E-Nagar Palika

To

Bhaskar Academy Indore(Name & Address of the Institution) Kh. No. 171/1/1, Ringnodiya, Sanwer, Indore

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

(reasons to be recorded).

(Name and designation of the authorized signatory)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

परिशिष्ट –ठ
प्रारूप – घ
फायर ऑडिट रिपोर्ट
वर्ष 2026-27

प्रति

BHASKAR ACADEMY
Khasra No. 171/1/1, Village – Ringnodiya
Tehsil- Sanwer, Indore – 452001 (M.P.)

महोदय

विषय :- BHASKAR ACADEMY, Khasra No. 171/1/1, Village – Ringnodiya, Tehsil- Sanwer, Indore – 452001 (M.P.) की फायर ऑडिट रिपोर्ट का प्रस्तुतीकरण।

सन्दर्भ :- म.प्र. नगरीय प्रशासन एवं आवास विभाग मंत्रालय भोपाल के पत्र क्र. 4981/ 895002/ 2022/ 18.3
भोपाल दिनांक - 16.12.2022.

मैं प्रणव उपाध्याय फायर एंड सेफ्टी इंजिनियर, आपके BHASKAR ACADEMY, Khasra No. 171/1/1, Village – Ringnodiya, Tehsil- Sanwer, Indore – 452001 (M.P.) जो की प्लॉट एरिया 4050 SQM (G+3) पर 10 मीटर उंचे निर्मित भवन में भूतल से तृतीय तल तक स्कूल संचालित का दिनांक **13.09.2026** को अग्निशमन यंत्रों / अधिष्ठायाओं का निरीक्षण किया और भवन परिसर का फायर ऑडिट पूर्ण किया गया है।

स्थापित किए गए अग्निशमन उपकरणों के ब्यौरे निम्नानुसार हैं :-
Subdivision B-1 (Educational Buildings)

Sr. No.	Particular	NBC PART 04 as per Requirement	Available / Installed or not installed as per requirement	Comments for working of system (attached details, if needed)
1	Access	Required	Available	Sufficient space for fire brigade connected to Main Road.
2	Wet Riser	Not Required		
3	Down Comer	Required	Available	Working Condition
4	Hose Reel	Required	Available	Working Condition – 8 Nos.
5	Automatic Sprinkler System	Not Required		
6	Yard Hydrant / Hydrant Post	Not Required		
7	Underground Tank	Required	Available	Capacity 20,000 Litre
8	Terrace Tank	Required	Available	Capacity 10,000 Litre
9	Fire Pump	Not Required		
10	Terrace Pump	Required	Available	1 Nos. Booster Pump 450 LPM

11	First Aid Fire Fighting Appliances	Required	Available	Fire Extinguisher in Working Condition ABC (4kg) = 08 Nos. CO2 (4.5 kg) = 01 Nos.
12	Pressurized System	Not Required		
13	Auto Detection System	Required	Available	Working Condition
14	Manually Operated Electrical Fire Alarm System	Required	Available	Working Condition
15	P.A. System	Required	Available	Working Condition
16	Emergency Light	Required	Available	Working Condition
17	Auto D.G. Set	Required	NA	
18	Illuminated Exit Sign	Required	Available	
19	Means of Escape	Required	Available	
20	Compartmentation	Not Required		
21	MCB / ELCB / RCCB/ MCCB	Required	Available	Working Condition
22	Firemen Switch in Lift	Required	Available	Working Condition
23	Hose Boxes with Delivery Hose & Branch	Required	Available	Working Condition
24	Refuse Area	Required	Available	
25	Any Other Installation		Nil	

It is certified that installed Fire-fighting Appliances are in working condition and safe.

Date: - 13/09/2026


PRANAV UPADHYAY
 B.E. FIRE & SAFETY
 Mob. 8871903534
 13/09/26

Signature